

## GUIDELINES FOR USE

**To assure correct operation of the lighting fixtures please read the guidelines below.**

1. Installation of the fixtures should only be done by an authorized electrician in accordance with the installation instructions and sector specific safety requirements.
2. Any repairs or service and maintenance must be done by a person with the appropriate qualifications and who has read these guidelines.
3. Any work carried out on the lighting fixtures should be performed only when the circuit is disconnected. During service and maintenance or remedial work, care should be taken to examine the mechanical status of the fixture fixings.
4. It is prohibited to install the fixture to any light sources other than those specified on the product label. Failure to comply with this may result in product failure, jeopardize the electrical installation, or pose a risk to health and safety.
5. It is forbidden to:
  - install the lighting fixtures to a power supply outside the parameters specified on the product label
  - install the lighting fixtures in environments inconsistent with the stated degree of ingress protection (IP rating).
  - install the lighting fixture with a distance smaller to the illuminated object than specified on the product label.
  - install the lighting fixture on a surface or structure other than is recommended by the manufacturer.

Failure to comply with the above might result in product failure, jeopardize the electrical installation, or pose a risk to health and safety.

6. It is forbidden to apply either mechanical elements or adapt the electrical installation procedure other than included in the instruction for use manual.
7. To ensure optimum performance efficiency, the fixture service and maintenance recommendations should be followed.
8. Incandescent, halogen and high intensity discharge light sources can cause high fixture surface temperatures. Care should be taken that the place of installation causes no risk is to health and safety.
9. Painted surfaces should always be cleaned with a soft damp cloth with the power disconnected. It is inadvisable to use chemically aggressive or solvent based cleaning agents.
10. On culmination of their commercial life, the lighting fixtures should not be haphazardly discarded. They must be disposed of according to the WEEE Directive regulations - either to a waste disposal point or returned to the manufacturer.



### **AQUAFORM Inc. sp. z o.o.**

ul. Przemysłowa 12-14  
32-070 Czernichów, Poland  
+48 12 270 21 22

info@aqform.pl  
www.aqform.com

NIP: 677-00-09-394  
Regon: 350540314

Nr KRS: 0000077402, Sąd Rejonowy dla Krakowa-Śródmieścia, XII Wydział Gospodarczy  
Wysokość kapitału zakładowego: 2 455 000,00 PLN